



NORTH DELHI MUNICIPAL CORPORATION  
OFFICE OF DEPUTY HEALTH OFFICER  
PUBLIC HEALTH DEPARTMENT: ROHINI ZONE  
SECTOR: V: ROHINI: DELHI: 110085  
E-mail: dhorohinizone15@gmail.com Ph: 011-27052106



NO: DHO/RZ/2019/2808

Date: 13/3/19

### SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Sohan Lal Tanwar ( Public health Inspector) from Public Health department Rohini Zone inspected the **C.R.P.F PUBLIC SCHOOL SECTOR-14, ROHINI, New Delhi, on 07.03.19** and found that the C.R.P.F SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from the date of issue.

*[Signature]*  
13/03/19

Dy. Health Office  
Rohini Zone



DY. HEALTH OFFICER  
Rohini Zone  
North Delhi Municipal Corporation

Principal  
C.R.P.F PUBLIC SCHOOL  
SECTOR-14, ROHINI,  
New Delhi



**DELHI JAL BOARD**  
(Govt. of N.C.T. Delhi)  
ZONAL LABORATORY, WATER WORKS,  
HAIDER PUR, DELHI-110085.

**THE TEST REPORT IS  
FOR THIS PARTICULAR  
WATER SAMPLE ONLY**

**TEST REPORT**

Water sample collected from supply point (through DJB) in the premises of CRPF School sector XIV Rohini vide challan no. 270 dated 28.01.19.

S. No.	PARAMETERS	UNITS	S1
1.	Date of collection	--	02.02.2019
2.	Date of Analysis	--	05.02.2019
3.	Colour	Hazen	Clear
4.	Odour	--	No Obj.
5.	Turbidity	N.T.U	1.23
6.	p <sup>H</sup> value	--	7.6
7.	Electrical Conductivity	µmhos/cm	316.0
8.	Total Dissolved Solid	(mg/l)	205.40
<b>CHEMICAL EXAMINATION</b>			
9.	Phenolphthalein Alkalinity	(mg/l)	Nil
10.	Total Alkalinity	(mg/l)	90.0
11.	Total Hardness	(mg/l)	123.5
12.	Calcium Hardness	(mg/l)	84.0
13.	Magnesium Hardness	(mg/l)	42.0
14.	Calcium as Ca	(mg/l)	33.6
15.	Magnesium as mg	(mg/l)	10.08
16.	Ammonia (free & saline)	(mg/l)	Nil
17.	Nitrite -Nitrogen (N)	(mg/l)	Nil
18.	Nitrate (NO <sub>3</sub> )	(mg/l)	3.73
19.	Sulphate (SO <sub>4</sub> )	(mg/l)	12.84
20.	Chloride (Cl)	(mg/l)	12.0
21.	Iron (Fe)	(mg/l)	0.02
22.	Fluorides (F)	(mg/l)	0.24
23.	Cyanides (CN)	(mg/l)	Abst.
24.	Residual Chlorine	(mg/l)	1.0
<b>BACTERIOLOGICAL EXAMINATION</b>			
25.	Coliform per 100 ml at 37 <sup>o</sup> C	MPN/100 mL	0

Remarks: On the basis of tested parameters, water sample (S1) conforms to drinking water specification IS 10500:2012, therefore it may be used for drinking purpose.

*[Signature]*  
Asstt. Chemist

*[Signature]*  
Chemist/Bacteriologist

*[Signature]*  
A.C.W.A. (HP I)